



Jim Doyle, Governor
Jack L. Fischer, A.I.A., Secretary

September 2, 2008

POLYJOHN ENTERPRISES CORP
RODNEY MULLETT
2500 GASPAR AVE
WHITING IN 46394-2175

Re: Description: SEWAGE TANKS, POLYETHYLENE
Manufacturer: POLYJOHN ENTERPRISES CORP
Product Name: HOLDING TANK
Model Number(s): Part Number - HT01-0250 (250 gallon capacity, White translucent in color)
Product File No: 20080459

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of September 2013.

This approval is contingent upon compliance with the following stipulation(s):

- This product may only receive waste from recreational vehicles.
- The joints between the tank cover and the inlets and outlet fittings must be made airtight.
- When this tank is installed to receive wastewater from only recreational vehicles, the tank must be installed by either a licensed plumber or a holder of a servicing license issued pursuant to s. 146.20, Wis. Stats., and ch. NR 113, Wis. Admin. Code. All servicing and disposal of the contents from these tanks must be in accord with s. 146.20, Wis. Stats., and ch. NR 113, Wis. Admin. Code.
- This product must be labeled with the manufacturer name and part number in a visible location after installation.
- This product may only be used as a POWTS holding component in campgrounds permitted by the Department of Health and Family Services under ch. HFS 178.

This approval supersedes the approval issued on March 12 2004 under product file number 20040044.

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20040044.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jerry Thompson
Plumbing Product Reviewer
Phone: 608-266-6742
Fax: 608-267-9566
E-mail: Jerry.Thompson@wi.gov